

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 3261-0550:107

Page 1 of 1

CATEGORY: Folding Door (Fire-Rated)

LISTEE: Cornell Iron Works, Inc., *24 Elmwood Ave., Crestwood Industrial Park,
Mountaintop, PA 18707
Contact: *Jim Dever (570) 474-6773 FAX (570) 715-0492
jimd@cornelliron.com

DESIGN: TranZform Fire Model ERP10 folding accordion door. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, fire rating and UL label.

APPROVAL: Listed as 1/3 hour, 1/2 hour, 3/4 hour, 1 hour, 1 1/2 hour, and 3 hour fire-rated interior automatic-closing horizontal folding doors. Authority having jurisdiction should be consulted prior to installation. Opening size not to exceed 9 feet high and 11 feet wide.

Doors exceeding the above limits are considered oversize construction and are based upon , and is similar to, the approval product design, but they have not been subject to approval testing due to test facility limitations. Acceptance of these doors is the prerogative of the authority having jurisdiction.

*Rev 5-7-09MA



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2009**

Listing Expires June 30, 2010

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division