



Northbrook Division
333 Pfingsten Road
Northbrook, IL 60062-2096 USA
www.ul.com
tel: 1 847 272 8800

October 20, 2008

Cornell Iron Works
Mr. Joe Kondash
Crestwood Industrial Park
Mountain Top PA, 18707

Subject: "S" Rated Curved Track TranZform fire rated doors

Our Reference: File R25122

Dear Mr. Kondash:

This letter is in reply to your written request concerning a clarification for the certification of your "S" rated TranZform fire-rated doors with curved tracks.

The TranZform fire-rated doors with curved tracks are capable of bearing the "S" Marking on the doors when the doors are constructed using your bottom seal construction as noted on Page 9 of your UL Follow-Up Service Procedure, File R25122, Volume 1, Section 1.

Only those products bearing the appropriate Classification Marking and the company's name, trade name, trademark, or other recognized identification should be considered as covered by UL's Classification and Follow-Up Service. Only those products bearing the appropriate Listed Marking and the company's name, trade name, trademark, or other recognized identification should be considered as covered by UL's Listed and Follow-Up Service

Authorities having jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Listed or Classified products, equipment, systems, devices and materials

I trust that this meets your request and if I can be of any further assistance, please let me know

Very Truly Yours,

Matthew Schumann
Senior Project Engineer
Fire Protection Division

Reviewed By:

Alec Hauser
Staff Engineer
Fire Protection Division

