

SECTION 08330

SentryGate®3 ROLLING SECURITY GRILLES

GENERAL NOTES TO SPECIFIER:

THIS SPECIFICATION SECTION HAS BEEN PREPARED TO ASSIST DESIGN PROFESSIONALS IN THE PREPARATION OF PROJECT OR OFFICE MASTER SPECIFICATIONS. IT FOLLOWS GUIDELINES ESTABLISHED BY THE CONSTRUCTION SPECIFICATIONS INSTITUTE, AND THEREFORE MAY BE USED WITH MOST MASTER SPECIFICATION SYSTEMS WITH MINOR EDITING.

EDIT CAREFULLY TO SUIT PROJECT REQUIREMENTS. MODIFY AS NECESSARY AND DELETE ITEMS THAT ARE NOT APPLICABLE. VERIFY THAT REFERENCED SECTION NUMBERS AND TITLES ARE CORRECT. (NUMBERS AND TITLES REFERENCED ARE BASED ON MASTERFORMAT, 1995 EDITION).

THIS SECTION ASSUMES THE PROJECT MANUAL WILL CONTAIN COMPLETE DIVISION 1 DOCUMENTS INCLUDING SECTIONS 01330 SUBMITTAL PROCEDURES, 01620 PRODUCT OPTIONS, 01630 PRODUCT SUBSTITUTION PROCEDURES, 01660 PRODUCT STORAGE AND HANDLING REQUIREMENTS, 01770 CLOSEOUT PROCEDURES, AND 01780 CLOSEOUT SUBMITTALS. IF THE PROJECT MANUAL DOES NOT CONTAIN THESE SECTIONS, ADDITIONAL INFORMATION SHOULD BE INCLUDED UNDER THE APPROPRIATE ARTICLES.

THIS IS AN OPEN PROPRIETARY SPECIFICATION ALLOWING USERS THE OPTION OF APPROVING OTHER MANUFACTURERS WHICH COMPLY WITH THE CRITERIA SPECIFIED HEREIN.

NOTES TO THE SPECIFIER ARE CONTAINED IN BOXES AND SHOULD BE DELETED FROM FINAL COPY.

OPTIONAL ITEMS REQUIRING SELECTION BY THE SPECIFIER ARE ENCLOSED WITHIN BRACKETS, E.G.: [35] [40] [45]. IN CASES WHERE ONE OF THE OPTIONAL ITEMS IS A STANDARD FEATURE OF THE DOOR MODEL, IT IS LISTED IN THE FIRST POSITION. MAKE APPROPRIATE SELECTION AND DELETE OTHERS.

ITEMS REQUIRING ADDITIONAL INFORMATION ARE UNDERLINED, E.G.: _____.

OPTIONAL PARAGRAPHS ARE SEPARATED BY A REDLINED "OR," E.G.:

OR

PART 1 GENERAL

1.1 SUMMARY

- A. Section Includes: [Manual] [and] [electrical] operated rolling security grilles.
- B. Related Sections:
 - 1. 05500 Metal Fabrications. Door opening jamb and head members.
 - 2. 06100 Rough Carpentry. Door opening jamb and head members.
 - 3. 08310 Access Doors and Panels. Access doors.
 - 4. 08700 Hardware. Padlocks. Masterkeyed cylinder.
 - 5. 09910 Paints. Field painting.
 - 6. Division 16. Electrical wiring and conduit, fuses, disconnect switches, connection of operator to power supply, and installation of control station and wiring.
- C. Products That May Be Supplied, But Are Not Installed Under This Section:
 - 1. Control Station

INCLUDE APPROPRIATE LANGUAGE BELOW, INCLUDING A REFERENCE TO SECTION 01230 ALTERNATES, IF ROLLING SECURITY GRILLES ARE INCLUDED IN ANY ALTERNATES, ADD SECTION 01230 TO 1.1 B. DELETE IF NO ALTERNATES.

D. Alternates:

1.2 SUBMITTALS

- A. Reference Section 01330 Submittal Procedures; submit the following items:
1. Product Data.
 2. Shop Drawings: Include special conditions not detailed in Product Data. Show interface with adjacent work.
 3. Quality Assurance/Control Submittals:
 - a. Provide proof of manufacturer ISO 9001:2000 registration.
 - b. Provide proof of manufacturer and installer qualifications - see 1.3 below.
 - c. Provide manufacturer's installation instructions.
 4. Closeout Submittals:
 - a. Operation and Maintenance Manual.
 - b. Certificate stating that installed materials complies with this specification.

1.3 QUALITY ASSURANCE

- A. Qualifications:
1. Manufacturer Qualifications: ISO 9001:2000 registered and a minimum of five years experience in producing security grilles of the type specified.
 2. Installer Qualifications: Manufacturer's approval.

1.4 DELIVERY STORAGE AND HANDLING

- A. Reference Section 01660 Product Storage and Handling Requirements.
- B. Follow manufacturer's instructions.

1.5 WARRANTY

- A. Standard Warranty: Two years from date of shipment against defects in material and workmanship.

PART 2 PRODUCTS

2.1 MANUFACTURER

- A. Manufacturer: Cornell Iron Works, Inc., Crestwood Industrial Park, Mountaintop, PA 18707. Telephone: (800) 233-8366, Fax: (800) 526-0841. Underwriters Laboratories, Inc. (UL), ISO 9001:2000 Registered.

INSERT NAME, ADDRESS, AND PHONE NUMBERS OF LOCAL DISTRIBUTOR BELOW.

1. Distributor:

B. Model: ESG20

C. Substitutions: Reference Section 01630 Product Substitution Procedures.

2.2 MATERIALS

A. Curtain:

1. Curtain to be fabricated from high strength injection molded components arranged in a "brick" style pattern. Color to be [black][white] matte finish. Assemble panels to create an open pattern curtain with slots having a clear aperture of 7" (177.8 mm) x 1-1/2" (38.1 mm). Finished curtains offer security along with visibility and airflow with a minimum 65% open curtain design. Panels to be interconnected using continuous horizontal aluminum rods, 5/16 inch (7.94 mm) diameter, 5056 H32 aluminum alloy, spaced 2" (50.8 mm) on center and locked in guides with steel retention rings. Continuous end chains assures smooth entry of curtain into guides. Curtain assembly shall be completely smooth and free of sharp edges. Curtain to be attached to shaft using minimum 22 gauge galvanized steel fastening sections, each 4" (101.6 mm) in length.
2. Bottom Bar to be a heavy duty extruded aluminum section with a continuous interior lift handle and to be designed to conceal locking mechanism and act as a stiffening member. Provide bottom vinyl astragal seal to act as cushion at counter or floor contact point.
3. Bottom Bar Finish:
 - a. Aluminum: [Clear anodized] [Black anodized] [Baked-on polyester powder coat, color as selected by Architect from manufacturer's standard color range, minimum 32 colors; minimum 2.5 mils (0.065 mm) cured film thickness; ASTM D-3363 pencil hardness: H or better.]

B. Guides:

1. Aluminum: Heavy duty extruded aluminum two piece guide sections designed to conceal wall attachment fasteners. Incorporate extruded aluminum retaining strip to prevent curtain from being pulled from guides.
2. Finish:
 - a. Aluminum:[Clear anodized] [Black anodized] [Baked-on polyester powder coat, color as selected by Architect from manufacturer's standard color range, minimum 32 colors; minimum 2.5 mils (0.065 mm) cured film thickness; ASTM D-3363 pencil hardness: H or better.]

C. Counterbalance Shaft Assembly:

1. Barrel: Minimum 3" (76.2 mm) diameter x .063" (1.6 mm) steel pipe capable of supporting curtain load with maximum deflection of 0.03 inches per foot (2.5 mm per meter) of width.
2. Spring Balance: Oil-tempered, heat-treated steel helical torsion spring assembly designed for proper balance of door to ensure that maximum effort to operate will not exceed 25 lbs (110N). Provide wheel for applying and adjusting spring torque.

D. Brackets: Fabricate from reinforced steel plate with bearings at rotating support points to support counterbalance shaft assembly and form end closures.

1. Finish:
 - a. Phosphate treatment followed by a light gray baked-on polyester powder coat; minimum 2.5 mils (0.065 mm) cured film thickness.

OR

- a. Phosphate treatment followed by a corrosion inhibitive baked-on zinc-rich gray polyester powder coat; minimum 2.5 mils (0.065 mm) cured film thickness.

OR

- a. ASTM A 123, Grade 85 zinc coating, hot-dip galvanized after fabrication.

OR

- a. Phosphate treatment followed by baked-on polyester powder coat, color as selected by Architect from manufacturer's standard color range, minimum 32 colors; minimum 2.5 mils (0.065 mm) cured film thickness; ASTM D-3363 pencil hardness: H or better.

- E. Hood: [24 gauge galvanized steel] [0.040 inch (1.016 mm) aluminum] with reinforced top and bottom edges. Provide minimum 1/4 inch (6.35 mm) steel intermediate support brackets as required to prevent excessive sag.

- 1. Finish:

- a. GalvaNex™ Coating System to include an ASTM A 653 galvanized base coating treated with dual process rinsing agents in preparation of a chemical bonding, light gray baked-on polyester base coat and a light gray baked-on polyester finish coat. The scientific organic material composition and chemical bonding process of GalvaNex™ produces a superior finish against corrosion and abrasion. GalvaNex™ components include a limited two year finish warranty.

OR

- a. GalvaNex™ Coating System and phosphate treatment followed by baked-on polyester powder coat, [color as selected by Architect from manufacturer's standard color range, minimum 32 colors] [custom color as selected by Architect]; minimum 2.5 mils (0.065 mm) cured film thickness; ASTM D-3363 pencil hardness: H or better.

OR

- a. Aluminum:[Clear anodized] [Black anodized].

2.3 ACCESSORIES

STANDARD LOCKING METHODS ARE LISTED BELOW.

- A. Locking:

- 1. [Manual Push-Up] [Manual Crank Hoist]: Locking thumb wing latch located on coil side of bottom bar at each jamb extending lock bolt through slots in guides. Keyed alike but not masterkeyed.

OR

AVAILABLE LOCKING OPTIONS ON ALL SENTRYGATE™3 UNITS. CONSULT CORNELL ENGINEERING SERVICES (800) 233-8366 EXT. 551 OR 641 FOR OTHER OPTIONS.

- 1. Locking thumb wing latch located on coil side of bottom bar at each jamb extending lock bolt through slots in guides. Keyed alike but not masterkeyed. [Provide interlock switches on motor operated units.]

OR

- 1. Masterkeyable cylinder operable from [coil] [fascia] [both] side[s] of bottom bar. [Provide interlock switches on motor operated units.]

PLASTIC LAMINATE COUNTERTOPS ARE AVAILABLE FOR OPENINGS UP TO 15'-0" (4.57 M) WIDE. 12" (305 mm) MINIMUM SILL DEPTH; 36" (914 mm) MAXIMUM SILL DEPTH.

- B. Countertop: Plastic laminate covered, 1-1/4" (32 mm) thick, of size and configuration for opening size and wall construction. Color as selected by Architect from standard range of Wilson Art, Nevamar, Formica or Pionite plastic laminates.

OR

STAINLESS STEEL COUNTERTOPS ARE AVAILABLE FOR OPENINGS UP TO 11'-0" (3.35 M) WIDE WITH SILL DEPTHS UP TO 20" (508 mm).

- B. Countertop: 14 gauge #4 finish stainless steel. ["T" shaped design for face of wall mounted unit] [Rectangular shape design for between jambs mounted unit] of size and configuration for opening size and wall construction.

EXPOSED MOVING OPERATOR COMPONENTS LOWER THAN 8 FEET ABOVE FLOOR LEVEL THAT CREATE POSSIBLE PINCH POINTS ARE REQUIRED TO BE COVERED PER UL 325. SPECIFY AN OPERATOR COVER WHENEVER THIS FIELD CONDITION EXISTS.

- C. Operator [and Bracket Mechanism] Cover: Provide [24 gauge galvanized steel] [0.040 inch (1.016 mm) aluminum] sheet metal cover [to provide weather resistance] [to enclose exposed moving operating components] at coil area of unit. Finish to match door hood.

2.4 OPERATION

- A. Manual Push-Up: Provide lift handles on bottom bar and pole with hook.

OR

- A. Manual Crank Hoist: Provide crank hoist operator including crank gear box, steel crank drive shaft and geared reduction unit. Fabricate gear box to completely enclose operating mechanism and be oil-tight.

OR

- A. Motor Operated: Model LGJ, cUL listed, 1/4 horsepower gearhead operator, wormgear in oil bath reducer, 115v single phase service and thermal overload protection. Provide built-in lock bar detection circuit to stop and reverse unit when operated in locked position, adjustable timer to close switch and provisions for push-up emergency manual operation.

OR

- A. Supply Model DJ, industrial duty, cUL listed, belt drive type jackshaft type operator(s) rated ___ H.P., ___ Volts, ___ Phase. Provide cUL listed electric door operator assembly of size and capacity recommended by door manufacturer; complete with electric motor and factory pre-wired motor controls, positive locking mechanical brake, emergency disconnect, internal door lock sensor and control station. Motor shall be high starting torque, continuous duty, industrial type, protected against overload by a current sensing or thermal overload device. Primary speed reduction shall be heavy-duty 5L V-belt and sprocket double reduced secondary providing mechanical braking to hold the door in any position. Operator shall be equipped with an adjustable friction clutch and floor level disconnect, output and door driven sprocket shall be provided with the

operator. Operator shall be capable of driving the door at a speed of 8 to 9 inches per second (20 to 23 cm/sec). Fully adjustable, driven linear type limit switch mechanism shall synchronize the operator with the door. Low friction nylon limit nuts fitted on threaded steel shaft, rotating on oilite self-lubricating bronze bushings. The motor shall be removable without affecting the limit switch settings.

MOST COMMON CONTROL STATIONS ARE LISTED BELOW; CONSULT CORNELL ENGINEERING SERVICES (800) 233-8366 EXT. 551 OR 641 FOR OTHER OPTIONS. DOORS WITHOUT BOTTOM WEATHER/SENSING EDGE MUST BE WIRED FOR CONSTANT PRESSURE ON THE "CLOSE" BUTTON.

1. Control Station: Flush mounted, "Open/Close" key switch; NEMA 1B.
OR
1. Control Station: Flush mounted, "Open/Close/Stop" push buttons; NEMA 1B.
OR
1. Control Station: Surface mounted, "Open/Close" push buttons; NEMA 1.
OR
1. Control Station: Surface mounted, "Open/Close/Stop" push buttons ; NEMA 1.
OR
1. Control Station: Surface mounted, "Open/Close" key switch; NEMA 3R.
OR
1. Control Station: Flush mounted, "Open/Close" key switch with "Stop" push button; NEMA 1B.

SENSING EDGE IS RECOMMENDED WITH MOTOR OPERATED UNITS; DELETE IF NOT DESIRED.

- B. Sensing Edge: Provide automatic [reversing] [stop] control by an automatic sensing switch within neoprene or rubber astragal extending full width of grille bottom bar.

WIRELESS SENSING EDGE CONNECTION UTILIZES AN EMBEDDED RESISTOR WITHIN AN ELECTRIC SENSING EDGE TO PROVIDE A FULLY SELF-MONITORING EDGE SYSTEM.

1. Provide an electric sensing edge device. Contact before door fully closes shall cause door to immediately [stop downward travel and reverse direction to the fully opened position] [stop downward travel]. Provide a self-monitoring wireless sensing edge connection to motor operator eliminating the need for a physical travelling electric cord connection between bottom bar sensing edge device and motor operator. Supervised system alters normal door operation preventing damage, injury or death due to an inoperable sensing edge system.
OR
1. Provide an electric sensing edge device. Contact before door fully closes shall cause door to immediately [stop downward travel and reverse direction to the fully opened position] [stop downward travel]. Provide [self-coiling cable] [retracting safety cord and reel] connection to control circuit.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Examine substrates upon which work will be installed and verify conditions are in accordance with approved shop drawings.
- B. Coordinate with responsible entity to perform corrective work on unsatisfactory substrates.
- C. Commencement of work by installer is acceptance of substrate.

3.2 INSTALLATION

- A. General: Install grille and operating equipment with necessary hardware, anchors, inserts, hangers and supports.
- B. Follow manufacturer's installation instructions.

3.3 ADJUSTING

- A. Following completion of installation, including related work by others, lubricate, test, and adjust grilles for ease of operation, free from warp, twist, or distortion.

3.4 CLEANING

- A. Clean surfaces soiled by work as recommended by manufacturer.
- B. Remove surplus materials and debris from the site.

3.5 DEMONSTRATION

- A. Demonstrate proper operation to Owner's Representative.
- B. Instruct Owner's Representative in maintenance procedures.

END OF SECTION