

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0550:0106 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: CORNELL IRON WORKS INC24 Elmwood Avenue, Crestwood Industrial Park, Mountaintop, PA 18707
Contact: Jim Dever (570) 474-6773 Ext: 4526 Fax (570) 715-0492
Email: jim.dever@cornellcookson.com

DESIGN: Models FIREGARD DC, FIREGARD BB, FIREGARD BV, FIREGARD MC, and FIREGARD MCV releasing devices. All units are intended to be used in conjunction with a temperature fusible link system to release a maximum 40 lbs. door load. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: FIREGARD DC = 24 VDC
FIREGARD BB = 120 VAC, 24 VAC, 24VDC
FIREGARD MC = 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as releasing devices. For indoor use only. Authority having jurisdiction shall be consulted prior to installation.

NOTE: Formerly 7300-1418:100

XLF: 7300-1609:0100

Rev * 5-7-09 MA



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division