



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	3505-0550:0108
CATEGORY:	3505 - SERVICE COUNTER DOOR (FIRE-RATED)
LISTEE:	CORNELL IRON WORKS INC 24 Elmwood Avenue, Mountaintop, PA, 18707 Contact: Mikleton, Nathan 5705507156 Email: nathan.mikleton@cornellcookson.com
DESIGN:	Mineral core countertop with plastic laminated surface. Core consists of two layers of 3/4" vermiculite boards. Plastic laminate max. 0.05". Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	1-1/2 hr.
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, fire rating and UL label.
APPROVAL:	Listed as a fire rated countertop for use with rolling steel type and service counter type fire doors rated up to 1-1/2 hrs. Refer to listee's Installation Instructions Manual for details.
NOTES:	

04-07-15 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/23/2025

Listing Expires: 06/30/2026

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division