



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

| | |
|----------------------|--|
| LISTING No.: | 4077-0550:0501 |
| CATEGORY: | 4077 - FIRE PROTECTIVE CURTAIN |
| LISTEE: | CORNELL IRON WORKS INC 24 Elmwood Avenue, Mountaintop, PA, 18707 Contact: Mikleton, Nathan 5705507156 Email: nathan.mikleton@cornellcookson.com |
| DESIGN: | Model ERF 20 SmokeShield Fabric Fire and Smoke Doors, Standard Fire-Protective Curtain. Refer to listee's data sheet for detailed product description and operational considerations. |
| RATING: | Up to and including 3 hr. fire rating |
| INSTALLATION: | In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction. |
| MARKING: | Listee's name, model number, and UL label. |
| APPROVAL: | Listed as a fire-protective curtain in gypsum or masonry walls for nonstructural applications where no hose stream requirements exists. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instructions Manual for details. |
| NOTES: | Test Std. UL 10D and UL 1784 |

04-24-18 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/01/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division